



- NOTES:**
1. WARNING TAPE TO BE TIED TO THE STUB OUT PIPE
  2. "X" FEET INDICATES 4' FOR F-TYPE CURB OR 6' FOR MIAMI CURB

**CONDUIT SLEEVE DETAIL**  
NTS

**GENERAL NOTES:**

REFER TO OUC LIGHTING CONSTRUCTION MANUAL FOR REQUIREMENTS AND SPECIFICATIONS. POLES SHALL BE INSTALLED AT LOCATIONS SHOWN ON THIS DRAWING. JUNCTION BOXES SHALL BE INSTALLED WITHIN 1-2 FEET FROM POLE LOCATION. CONDUIT SHALL NOT BE ROUTED WHERE POLES ARE TO BE INSTALLED. JUNCTION BOXES SHALL MAINTAIN A MINIMUM CLEARANCE OF 7 FEET FROM ALL FIRE HYDRANTS.

SUBMIT AS-BUILT DRAWINGS TO ENGINEER IF CHANGES ARE MADE IN THE FIELD.

COORDINATE INSPECTION OF UNDERGROUND WITH OUC LIGHTING CONSTRUCTION COORDINATOR (LEE HALE, PHONE # 321-436-6324).

- NOTES:**
- INSTALL SECONDARY JUNCTION BOX PER OUC SPECIFICATIONS
  - INSTALL STREETLIGHT JUNCTION BOX PER OUC SPECIFICATIONS
  - INSTALL 2" PVC CONDUIT W/ PULL STRING PER OUC SPECIFICATIONS. PROVIDE GALVANIZED ELBOWS FOR CONDUIT RUNS 125 FEET OR GREATER.
  - INSTALL 1" PVC CONDUIT SLEEVE PER OUC SPECIFICATIONS (SEE DETAIL.)
  - DIRECT BURIED POLE AND FIXTURE (INSTALLED BY OUC)
  - ELEC. DISTRIBUTION SECONDARY JUNCTION BOX
  - PAD MOUNTED TRANSFORMER

**OUC LIGHTING CONDUIT PLAN**



O.U.C.  
Lighting  
6003 Pershing Ave.  
Orlando, FL 32822  
(407) 737-4234

WORK ORDER #	537175	JOB TYPE:	LCONTRACT
JOB NAME:	HARMONY NEIGHBORHOOD 01	ENGINEER:	RIG DY-LIACCO
LOCATION:	FIVE OAKS DR	SCALE:	1" = 80'
INSTALLATION DATE:	X	DATE:	04-20-16
GLOBE/OPTIC/SCU:	SEE LEGEND	GROUP #:	X
FIXTURE STYLE:	TEAR DROP	DATE REV.:	BY
CONTROLER:	N	REVISION	1
CUCODE:	SEE LEGEND		
JURISDICTION:	OSCEOLA COUNTY		
COVERAGE:	ROADWAY		
BRACKET/CU:	SEE LEGEND		
		PAGE:	1 OF 1